STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119716
Permit No.
Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71191

1. OWNER Jackie Taylor
MAILING ADDRESS 534 Green Acres Dr
Gardnerville NV 89423

ADDRESS AT WELL LOCATION Same
Subdivision Name:
County: Douglas

2. LOCATION NW¼NE¼ Sec 26T12 / R19E
Latitude 38.881104
Longitude -119.811623
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

PERMIT/WAIVER NO. 1219-26-001-027
Issued by Water Resources
Parcel. No.

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sands	x	0	30	30
Sands & Small Gravel	x	30	40	10
Gray Sands & Small Gravel	x	40	80	40
Gray Sands with Clay	x	80	100	20
Gray Sands, Gravel & Clay	x	100	130	30
Brown Sand, Gravel & Clay	x	130	160	30

RECEIVED 2014 MAR 17 PM 12:19 STATE ENGINEERS OFFICE

replaces rentenera well log

Nad 27
38.881 lat
119.810612 w

Date started: 2/17, 20 14
Date completed: 2/19, 20 14

7. Water Level
Static water level: Artesian feet below land surface
Artesian Flow: 50+ G.P.M. Not Tested P.S.I
Water Temperature: Cool °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+	-0-	3

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17.5 Inches	0 Feet	40 Feet
10 5/8 Inches	40 Feet	160 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	25.22	.188	0	40
6 5/8	12.92	.188	0	160

Perforations:
Type of perforation Factory Cut
Size of perforation 3 3/2 x 3
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 110 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 110 to 160 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 2/26/14

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com