

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119742
Permit No. 83290T
Basin 0334

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70767

1. OWNER Ron & Denise Ceppi ADDRESS AT WELL LOCATION 90 Rock Creek Rd.
MAILING ADDRESS 6 Rebel Creek Ln. Orovada NV. Subdivision Name: _____ County: Humboldt

2. LOCATION SE 1/4 NE 1/4 Sec 35 T 43 S R 37 E Latitude N 41° 56' 42.36" UTM E NAD 27
PERMIT/WAIVER No. 83290T 003-401-83 Longitude W 117° 22' 10.51" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand + Rock</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>Clay Sand Boulders</u>	<u>NO</u>	<u>5</u>	<u>160</u>	<u>155</u>
<u>Cemented Ground</u>	<u>NO</u>	<u>155</u>	<u>325</u>	<u>170</u>
<u>Cobbles</u>	<u>NO</u>	<u>155</u>	<u>325</u>	<u>170</u>
<u>Hard rock fractures</u>	<u>YES</u>	<u>325</u>	<u>460</u>	<u>135</u>

RECEIVED
2014 MAR 20 11:11:23
ENGINEERS OFFICE

Lat 27
41° 56' 42.36" N
117° 22' 10.51" W

Date started: 3-3 , 20 14
Date completed: 3-19 , 20 14

9. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
10 7/8" Inches 0 Feet 460 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8"</u>	<u>Steel</u>	<u>.188</u>	<u>0</u>	<u>20</u>
<u>6 7/8"</u>	<u>PVC</u>	<u>Sched 40</u>	<u>20</u>	<u>460</u>

Perforations:
Type of perforation slot
Size of perforation .020
From 360 feet to 460 feet

Annular Seal: Yes No

Neat Cement 0 to 20 Pumped Poured
Cement Grout _____ to _____ Pumped Poured
Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 100 to 460 Pumped Poured
Type: 3/8" Pear
Bentonite Chips: Yes No 20 to 100 Pumped Poured
Type: 3/8" chip

7. Water Level
Static water level: 352 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>NA</u>	<u>8</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Allied Drilling Inc. Contractor
Address: 5140 Junco Rd. Contractor
Winnemucca NV.
Nevada contractor's license number 76278
issued by the State Contractor's Board
Nevada driller's license number issued by the 1563
Division of Water Resources, the on-site driller

Signed: [Signature]
By driller performing actual drilling on-site or contractor
Date: 3-19-14