STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119744
Permit No.
Basin No. 040

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67136
WELL NAME (If applicable): MW-24

1. OWNER/CLIENT NAME Richard & Janice Fiore
MAILING ADDRESS 510 Mission Street
San Francisco, CA 94105

DETAILED ADDRESS AT WELL LOCATION Facility ID: 4-000061
940 Southwood Blvd. Incline Village, NV
Subdivision Name: County: Washoe

2. PLS LOCATION NW ¼ SE ¼ 15 Sec 16N N/S 18 E
PERMIT/WAIVER NO. 132-231-12
Issued by Water Resources Current Parcel No

Latitude 39.249407 UTM E ☐ NAD 27
Longitude -119.9475182 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☒ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand, brown			0	15	15
Silty Sand, brown			15	20	5
Sand with silt, brown			20	30	10
Sand, brown			30	40	10

Nad 27
39.249499°N
119.946496°W

Date started: 21-Nov, 20 11
Date completed: 23-Nov, 20 11

9. WELL CONSTRUCTION
Depth Drilled: 40 Feet Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch	0	40

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.02
From 20 Feet To 40 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to	☐ Pumped	☐ Poured
☒ Neat Cement	0	to 3	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	3	to 18	☐ Pumped	☒ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	18	to 40	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 25 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3000 Duluth Street West Sacramento, CA 95691 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 73966
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2373
Signed: (By driller performing actual drilling on site or contractor)
Date:

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY