STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119794
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70148

1. OWNER Sean Riley
MAILING ADDRESS 7215 Jackson Rd. Winnemucca NV.
ADDRESS AT WELL LOCATION 7215 Jackson Rd. Winnemucca NV.
Subdivision Name: Sonoma Ranchos County: Humboldt

2. LOCATION NW ¼ NE ¼ Sec 13 T 35 N/S R 37 E
PERMIT/WAIVER No. 013-541-24
Issued by Water Resources Parcel No.
Latitude N40° 54.735
Longitude W117° 45.721
UTM E
N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ■ Other Plugging

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing Well		0	130	

RECEIVED
2013 OCT -9 PM 12:43
STATE ENGINEERS OFFICE

plugs unknown well log
Replaced by log 118243
NAD27
40.912250 N
117.732017 W

Date started: 9-12, 20 13
Date completed: 9-12, 20 13

9. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	130 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	130

Perforations:
Type of perforation NA
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ■ No
■ Neat Cement 115 to 130 ■ Pumped ☐ Poured
☐ Cement Grout 0 to 20 ■ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ■ Yes ☐ No 20 to 115 ☐ Pumped ■ Poured
Type: 3/8" Chips

7. Water Level
Static water level: 120 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: NA °F
Quality: NA

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 9-12-13

(Rev 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627