STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11997
Permit No. 83333
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70652

1. OWNER Round Mountain Gold Corp. DW-69
MAILING ADDRESS P.O. Box 480, Round Mountain, NV. 89045

ADDRESS AT WELL LOCATION Round Mountain Gold, Round Mountain, NV
Subdivision Name: County: Nye

2. LOCATION NW¼NE¼ Sec30T10N/ R44E
PERMIT/WAIVER NO. 83333 (Issued by Water Resources) Order 1233 (Parcel. No.)

Latitude
Longitude
UTM E 493141 ☒ NAD 27
N 4283379 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Flooded Rev.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey Rock W/Grey Clay		0	40	40
Grey & Tan Rock W/Clay		40	50	10
Grey Rock W/Clay		50	140	90
Grey Rock		140	160	20
Dark Grey Rock		160	240	80
Light Grey Rock		240	270	30
Dark Grey Rock		270	300	30
Light Grey Rock		300	420	120
Dark Grey Rock		420	490	70
Light Grey Rock W/Clay		490	510	20

RECEIVED 2014 APR 30 AM 11:29 STATE ENGINEERS OFFICE

Nad 27
38.908876° N
117.078878° W

Date started: April 9, 20 14
Date completed: April 20, 20 14

9. WELL CONSTRUCTION

Depth Drilled 510 Feet Depth Cased 494 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26 Inches	0 Feet	20 Feet
17.5 Inches	20 Feet	510 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.61	.375	0	20
10.75	28.04	.250	+2	494

Perforations:
Type of perforation Louver
Size of perforation .125
From 71.66 feet to 473.47 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 53 to 494 ☐ Pumped ☒ Poured
Type: 1/2" X 3/4" SRI Supreme

Bentonite Chips: ☒ Yes ☐ No 50 to 53 ☐ Pumped ☒ Poured
Type: 3/8" Hole Plug - Sodium Bentonite

7. Water Level
Static water level: Surface feet below land surface
Artesian Flow: G.P.M. N/A P.S.I
Water Temperature: 110 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70	348	3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave., (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2486
Signed
By driller performing actual drilling on site or contractor
Date April 23, 2014

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com