DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 7242
Permit No.
Basin

1. OWNER Bader & Dianda ADDRESS 9000 Spearhead Drive; Golden Valley; Reno, Nevada

2. LOCATION portion SW SE ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (9040 Spearhead Drive- Golden Valley)

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6	6
Decomposed granite sand- reddish silt mixed		6	87	81
Fine to coarse yellow sand-some water(4GPM)		87	90	3
Brown rock		90	145	55
Broken grey rock-(8GPM)	X	145	150	5

Date started 8-17-71, 19
Date completed 8-18-71, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	12GPM	60'	1½ Hrs.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 150 feet
Casing record 0-97' X 6"
Weight per foot 12-lbs. Thickness .188

Diameter	From	To
6 5/80D inches	0 feet	97 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 60 feet
Gravel packed: Yes [ ], No [X]
Gravel packed from feet to feet

Perforations:
Type perforation oxy-acet. torch
Size perforation 1/8" X 6"
From 77 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60' Feet below land surface
Flow G.P.M.
Water temperature cold. F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address 1955 18th Street; Sparks, Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed [signature]
Date 8-24-71

USE ADDITIONAL SHEETS IF NECESSARY

5471

1972 [illegible] 24 AM 9 22