DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12543
Permit No.
Basin CARD

1. OWNER ENGLUND ADDRESS
aff Silverter Dr
2. LOCATION ¼ ¼ Sec. T. N/S R. E. WASHOE County
PERMIT NO.

3. TYPE OF WORK: New Well ☐ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☑ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

M.H. = MIDDLE HARD

Material	Water Strata	From	To	Thickness
CLAY & BOULDERS		0'	10'	10'
YELLOW MIDDLE HARD SHALE		10'	25'	15'
DARK YELLOW M.H. SHALE		25'	45	20'
DARK YELLOW SOFT SHALE		45'	50'	5'
DARK YELLOW HARD SHALE		50'	52'	2'
LT. YELLOW HARD SHALE		52'	75'	23'
YELLOW HARD SHALE		75'	81'	6'
CREAM M.H. ROCK		81'	100'	19'
LT. GRAY M.H. CLAY		100'	122'	22
WHITE M.H. CLAY		122'	141'	19'
BROWNISH GRAY HARD		141'	146'	5'
LT GRAY HARD		146'	155	9'
LT. GRAY HARD WITH STREAK	S/G	155'	163	8'
LT GRAY M.H. W/ SAND & GRAVEL	2 GPM	163	178	15'
SAME		178	208	30'
SM BOULDERS SAND & GRAVEL	6 GPM	208	223	15'
HARD STREAK		223	225	2'
HARD GREY SHALE		225	230	5'
HARD GREY SHALE W/ STREAKS of SAND & GRAVEL HOT WATER 120°		230	245	15'
HARD SAND STONE		245	255	13'
HARD SAND STONE W/ STREAKS of SAND & GRAVEL	SOME WATER	255	282	24'
CLAY WITH STREAKS of SAND & GRAVEL	SOME WATER	282	305	13'
		305	325	20'
HARD ROCK		325	328	2'

Date started June 10, 19 72
Date completed June 14, 19 72

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air test	15+		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 4½ inches Total depth 325 feet
Casing record
Weight per foot Thickness

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 165' Feet below land surface
Flow G.P.M. 15+
Water temperature 98 ° F. Quality FAIR

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name COLEMAN & SONS
Address 3390 APT 2 NEILRD RENO
Nevada contractor's license number
Nevada driller's license number 672
Signed George R Coleman
Date June 28 1972

USE ADDITIONAL SHEETS IF NECESSARY

5471