DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12736 also 12462
Permit No.
Basin Golden Valley Pump

1. OWNER Mr Glenn Coutch ADDRESS 2070 Mill St Reno Nev
3495 WARPAINT Circle
LOT #25 GOLDEN VALLEY SUB #1 WAR PAINT CIR

2. LOCATION ¼ ¼ Sec 11 T 20 N/S R 19 E WAS 20 E County
PERMIT NO. APN 088-171-71

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WAS CASED TO 185'	6"	10	GA	
BORE HOLE TO 185'	10"			
GRAVEL PACKED 50 TO 185'				
PERFORATED 140 TO 185'	— 45'			
OLD LOG REMOS				
TOP SOIL	0	0	2	2
CLAY & SAND		2	120	118
STREAKS OF SAND & GRAVEL		120	185	65
PUMPED 4 HR 8 GPM				
DRAW DOWN -100'				
STATIC WATER LEVEL 70'				
(WELL WENT DRY)				
DEEPEN JOB				
CLAY DECOMPOSED ROCK		185	218	23
CLAY HARD & SAND		218	230	12
LARGE GRAVEL HARD CLAY		230	233	3
WATER SAND & GRAVEL	←	233	257	24

Date started Nov 1, 19 72
Date completed Nov 5, 19 72

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Jet	12	207	4 hrs

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 257' feet
Casing record 6" TO 185 — 5" 185 TO 257
Weight per foot ..... Thickness 10 GA.

Diameter		From		To	
6 5/8	inches	+ 1	feet	185	feet
5	inches	177	feet	257'	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type CEMENT GROUT
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 185' feet

Perforations:
Type perforation TORCH
Size perforation 8 x 3/16 x 3 R
From 140 feet to 185 feet
From 217 feet to 257 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 78 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name George R. Coleman
Address 3390 APT #2 NEIL RD RENO NEV
Nevada contractor's license number 11462
Nevada driller's license number 672
Signed George R Coleman
Date Nov 10 1972

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1972 NOV 22 AM 10-05