DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12961
Permit No.
Basin Washoe Val

1. OWNER Hellen Halman ADDRESS 3340 Pershing Lane
Lot 10 Block C
Washoe Farms Subdivision - Washoe Valley
2. LOCATION ¼ ¼ Sec. 6 T. 16 N/S R. 20 E. Washoe County
PERMIT NO. APN # 050-944-05

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard pan		0	14	14
Sandy Clay		14	27	13
Clay (Yellow)		27	49	22
Sand	Water	49	56	7
Clay (Brown)		56	82	26
Sand + Gravel	"	82	91	9
Clay (Brown)		91	94	3

Date started 11-30, 19 72
Date completed 12-21, 19 72

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 65 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 5/8 inches Total depth 94 feet
Casing record Black line pipe welded joints
Weight per foot 12.54 Thickness .185

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 45 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch Cut
Size perforation 1" x 6" - 4 Rows
From 75 feet to 92 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 15 Feet below land surface
Flow None G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Smith Pump Inc.
Address 295 East 2nd Ave Sparks
Nevada contractor's license number 6425 A
Nevada driller's license number 27-6205
Signed Claude Smith
Date 1-7-73

USE ADDITIONAL SHEETS IF NECESSARY

5471