DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12979.
Permit No.
Basin Truckee Mead

1. OWNER Bob Bell ADDRESS P.O. Box 142; Steamboat, Nev.

2. LOCATION ¼ ¼ Sec. 34 T. 18N N/S R. 20 E. Washoe County
PERMIT NO. Lots 3 & 4

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Broken brown rock w/ silt- very dry		0	10	10
Broken black andesite		10	55	45
Broken brown rock w. silt		55	58	3
Fractured black andesite very dry and dusty. damp 168-173: water bearing 201-212		58	215	157

Date started 7-4-72, 19
Date completed 7-5-72, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	12 GPM	73'	1½

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 215 feet
Casing record
Weight per foot 12.82 Thickness .188

Diameter	From	To
6 5/8OD inches	0 feet	213 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement slurry
Depth of seal 59 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation factory mill slot
Size perforation 1/8 X 3; 6 per row
From 173 feet to 213 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 112 Feet below land surface
Flow G.P.M.
Water temperature 68 ° F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. L. McDonald & Co.
Address 1955 18th Street; Sparks, Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed [signature]
Date 7-6-72

USE ADDITIONAL SHEETS IF NECESSARY

5471