

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 120002  
Permit No. \_\_\_\_\_  
Basin 135A

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71837

1. OWNER John Peterson ADDRESS AT WELL LOCATION 1960 Craig Road Tonopah NV 89049  
MAILING ADDRESS P.O. Box 1524 Tonopah NV 89049 Subdivision Name: 6 County: NYE  
2. LOCATION NE 1/4 NE 1/4 Sec 13 T 6 N R 40 E Latitude N38° 23.074 UTM E  NAD 27  
PERMIT/WAIVER No. 5 12-421-31 Longitude 117.251472 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	10	10
Boulders - clay - sand		10	70	60
Clay - sand		70	85	15
gravel - Boulders	X	85	140	55
Fractured Rock	X	140	198	58
7' of steel 8" casing wgs cemented over 6" pvc at surface				

9. WELL CONSTRUCTION  
Depth Drilled 198 Feet Depth Cased 198 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 198  
Inches 11 Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6 1/2 PVC SCH 40 0 198

Perforations:  
Type of perforation saw cut  
Size of perforation 1/8" x 3"  
From 55 feet to 198 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout -3 to 55  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 55 to 198  Pumped  Poured  
Type: 3/8 minus  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 4-22-2014, 20  
Date completed: 4-23-2014, 20

7. Water Level  
Static water level: 100 feet below land surface  
Artesian Flow: 0 G.P.M. 0 P.S.I.  
Water Temperature: cold °F  
Quality: good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>2</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Davis Drilling and Pumps Contractor  
Address HC 61 Box 59 Hiko NV 89017 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0028866  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
Signed Mike Davis  
By driller performing actual drilling on-site or contractor  
Date 4-24-2014

(Rev. 05-96)

USE ADDITIONAL SHEETS IF NECESSARY