STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120043
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37144

1. OWNER County of Clark (Pk & Comm Serv)
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas, NV 89155-0000

ADDRESS AT WELL LOCATION 5483 Club House Drive
Subdivision Name: County: Clark

2. LOCATION SE ¼ NW ¼ Sec 4 T 21S N/S R 62 E
PERMIT/WAIVER No. DW-1333 16109501001
Issued by Water Resources Parcel No.

Latitude 36.153771N UTM E ☐ NAD 27
Longitude 115.057478W N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well 102 FOR				
LOG ATTACHED #160				
				#####

SCNR/DWR/SNRC RECEIVED MAR 3 1 2014

Date started: 23-Jan , 20 14
Date completed: 23-Jan , 20 14

9. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	50	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	50

Perforations:
Type of perforation machine slot
Size of perforation 0.032"
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 12 ☐ Pumped ☒ Poured
Gravel Pack: ☒ Yes ☐ No 3' to 30' ☐ Pumped ☒ Poured
Type: 3/8" Pea Gravel
Bentonite Chips: ☒ Yes ☐ No 10' to 12' ☐ Pumped ☒ Poured
Type: 3/8"

7. Water Level
Static water level: 8 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers, Inc
Contractor
Address 5950 Granite Lake Drive
Contractor
Granite Bay, CA 95746
Nevada contractor's license number issued by the State Contractor's Board 0034680
Nevada driller's license number issued by the Division of Water Resources, the on-site driller DW-2361
Signed
By driller performing actual drilling on site or contractor
Date 3/11/2014

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1537985
-115.0566463
NAD 27

THIS BORING LOG IS FOR VIKING'S INTERNAL PURPOSES ONLY. IT DOES NOT REPRESENT INFORMATION PROVIDED BY A SOILS ENGINEER.

LOG FOR BORING NO. 161 159,160		JOB NAME: LV Paving			
DATE STARTED 1-23-14	DATE COMPLETED	LOGGED BY Ed	DRILLED BY Ed	TYPE OF DRILL RIG #32	JOB NO. 6150
DEPTH OF HOLE 50'	DIAMETER OF HOLE 24"	CASING 8"	PERFORATIONS 20'	SAMPLING METHOD	ELEVATION
LOCATION 159 43+46 160 42+86 161 42+26 Vegas wash				DRILLERS NOTES:	

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION
0'			silt touch of clay
10'			silty sand
20'			silty clay
30'			hard silty clay
40'			
50'			
60'			
70'			
80'			
90'			
100'			

DCNR/DWT/SNRC
RECEIVED
MAR 3 1 2014

REVIEWED
By sphilliber at 10:38 am, Feb 03, 2014

REVIEWED
By Matt Peyrucain at 2:03 pm, Feb 03, 2014

FEB 0 3 2014