STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120238
Permit No. 83667T
Basin 066

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70892

1. OWNER Seven Dot Cattle Co. Jim Christison
MAILING ADDRESS HC 66 Box 10
Golconda NV. 89414

ADDRESS AT WELL LOCATION Julian Creek
Golconda NV.
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SE ¼ Sec 16 T 38 N/S R 42 E
PERMIT/WAIVER No. 83667 T (Issued by Water Resources) 3742-03-200-001 (Parcel No.)
Latitude N41.169917
Longitude W117.248202
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	7	7
Boulders Clay Sand	NO	7	90	83
Cobbles, Clay, Sand	NO	90	160	70
Clay, Sand, fine gravel	Yes	160	300	140

Rad 27
41.169917 N
117.248202 W

Date started: 4-24-14, 20 14
Date completed: 4-30-14, 20 14

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Schd 40	20	300

Perforations:
Type of perforation Slot
Size of perforation .20
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☒ No 100 to 300 ☐ Pumped ☒ Poured
Type: 3/8" Pea Gravel
Bentonite Chips: ☒ Yes ☐ No 20 to 100 ☐ Pumped ☒ Poured
Type: 3/8" chip

7. Water Level
Static water level 118 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3	80	12

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 5-15-14

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627