STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120376
Permit No.
Basin 089

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71199

1. OWNER Frank Dziurda
MAILING ADDRESS 225 W Coyote
Washoe Valley NV 89704

ADDRESS AT WELL LOCATION Same
Subdivision Name:
County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 31 T 17N / R 20 E
PERMIT/WAIVER NO. 050-385-13 (Issued by Water Resources) ~~050-285-13~~ (Parcel. No.)

Latitude 39.29469
Longitude -119.778879
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		112	130	18
Gray Granite		130	206	76
Small Fracture		206	207	1
Gray Granite		207	241	34
Small Fracture		241	242	1
Gray Granite		242	273	31
Fracture	X	273	274	1
Gray Granite		274	300	26

Washoe Permit #WL140015

Deepen unknown well log

NAD27
39.294780
119.777861

Date started: 6/17, 20 14
Date completed: 6/19, 20 14

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	130 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	100	300

Perforations:
Type of perforation Factory
Size of perforation .060 double row
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 45 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	15		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 6/23/14

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com