STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120409
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70899

1. OWNER Chris St Peter/James McNerney
MAILING ADDRESS 78 Licht Parkway
Spring Creek NV.

ADDRESS AT WELL LOCATION Sierra Pass Rd.
Winnemucca NV.
Subdivision Name: Blue Mtn Ranches County: Humboldt

2. LOCATION SW ¼ NW ¼ Sec 21 T 36 N/S R 36 E
PERMIT/WAIVER No. 3636-21-100-003
Issued by Water Resources Parcel No.

Latitude N40° 59.049
Longitude W117°56.573
UTM E N
■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	5	5
Clay Sand Gravel	NO	5	115	110
Clay w alternating	NO	110	230	120
shale layers	yes	230	360	130

NAD 27
40.984150°N
117.942883°W

Date started: 5-23 , 20 14
Date completed: 5-30 , 20 14

7. Water Level
Static water level: 225 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	NA	12

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	360 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	Steel	.188	0	20
6 3/8	PVC	Sched 40	20	360

Perforations
Type of perforation Slot
Size of perforation .20
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 360 ☐ Pumped ■ Poured
Type: 3/8" pea
Bentonite Chips: ■ Yes ☐ No 20 to 50 ☐ Pumped ■ Poured
Type: 3/8" chip

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. Contractor
Address 5140 Jungo Rd. Contractor
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76278
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 8563
Signed By driller performing actual drilling on-site or contractor
Date 6-4-14

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-05)

(NSPO 3-08)

(O) 627