STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120416
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70900

1. OWNER James Davis
MAILING ADDRESS 5800 Hwy 95 N #F3
Winnemucca NV 89445

ADDRESS AT WELL LOCATION 9665 Sabin Dr.
Winnemucca NV.
Subdivision Name: Tycana County: Humboldt

2. LOCATION NE ¼ SE ¼ Sec. 30 T 35 N S R 38 E
PERMIT/WAIVER No. 3538-30-400-024
Issued by Water Resources Parcel No.

Latitude N 40° 52. 604
Longitude W 117° 44. 264
UTM E N
■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Cobbles gravel	NO	0	60	60
Clay Cobbles gravel	NO	60	135	75
Gravel Clay Sand Cobbles	NO	135	280	145
Clay Gravel Sand	Yes	280	420	140

NAD27
40.876735°N
117.737733°W

Date started: 6-13, 20 14
Date completed: 6-18, 20 14

9. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	420	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Sched 40	20	420

Perforations:
Type of perforation Slot
Size of perforation .20
From 360 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 420 ☐ Pumped ■ Poured
Type: 3/8 Pea
Bentonite Chips: ■ Yes ☐ No 20 to 50 ☐ Pumped ■ Poured
Type: 3/8" Chip

7. Water Level
Static water level: 272 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	NA	6

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed
By driller performing actual drilling on-site or contractor
Date 6-20-14

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627