STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120467
Permit No.
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70866
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Rick Lloyd
MAILING ADDRESS 300 Coot Way WV NV

DETAILED ADDRESS AT WELL LOCATION 4215 Partridge Lane
Subdivision Name: *County:* Washoe

2. PLS LOCATION ~~SE~~ NE ¼ NW ¼ 5 Sec 16 N/S 20 E
PERMIT/WAIVER NO. 5043120
Issued by Water Resources *Current Parcel No.*

Latitude 39 28640 UTM E ☐ NAD 27
Longitude 119 76202 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand			0	4
Clay			4	6
Cobbles			6	9
Sand			9	61
Gravel			61	105
Gravel-clay			105	115
Dense gray clay			115	140
Sand			140	180
Brown sand			180	205
Sand-Small gravel			205	300
clay sand			300	315
small gravels-sand			315	350
clay			350	359
small gravels-sand			359	400
NAD 27				
39.286489°N				
119.761003°W				

Date started: 7-Jul, 20 14
Date completed: 14-Jul, 20 14

9. CONSTRUCTION
Depth Drilled: 400 Feet Depth Cased: 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	55	Feet
9 7/8	Inches	55	Feet	300	Feet
6 1/4	Inches	300	Feet	400	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	+2	18
6	4	SDR21	18	300
5	8	.188	280	400

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 55	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	55	to 300	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:

Type of perforation: Factory mill
Size of perforation: 0.09

From	260	Feet	To	300	Feet
From	320	Feet	To	340	Feet
From	360	Feet	To	400	Feet
From		Feet	To		Feet
From		Feet	To		Feet

7. *WATER QUALITIES*
Static water level: 185 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
12	N/A	16

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling
Contractor
Address PO 1255 CC NV 89702
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134
Signed:
By driller performing actual drilling on site or contractor
Date: 7/18/2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.