STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120473
Permit No.
Basin No. 087

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65679
WELL NAME (If applicable):

1. OWNER/CLIENT NAME City of Reno Public Works/Dustin Water
MAILING ADDRESS PO Box 1900, Reno, NV 89505
DETAILED ADDRESS AT WELL LOCATION Reno Tahoe Airport, off National Guard Way, 640' East of Aviation Way
Subdivision Name: County: Washoe

2. PLS LOCATION ~~NE~~ NW ¼ SE ¼ 19 Sec 19 N/S 20 E
PERMIT/WAIVER NO. M/O-1925A (Issued by Water Resources) 015-210-34 (Current Parcel No.)
Latitude 39.4981 UTM E ☐ NAD 27
Longitude -1189.7764 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
sand and gravel, tan			0	10
sand, fine grain tan.			10'	18
silty sandy clay			17.5	~~30~~ 20

Nad 27
39.4981 89°N
119.7753 27°W

Date started: 29-May, 20 14
Date completed: 29-May, 20 14

9. INSTRUCTION
Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch40	0	20

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☒ Neat Cement	1	to	6	☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips	6	to	9	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	9	to	20	☐ Pumped	☐ Poured
☐ Other, explain:	0	to	1	☐ Pumped	☐ Poured

flush mount vault set in concrete

PERFORATIONS:
Type of perforation: factory slot
Size of perforation: .020

From	Feet	To	Feet
10		20	

7. WATER QUALITIES
Static water level: 9.5 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HAZ-TECH DRILLING INC. (Contractor)
Address PO BOX 940, MERIDIAN, ID, 83680 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0038018
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): M-2188
Signed: [signature] By driller performing actual drilling on site or contractor
Date: 6/11/14

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.