STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120516
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71331
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Robert Stewart
MAILING ADDRESS 2045 Soda Lake Road
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 2045 Soda Lake Road
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION SE ¼ SE ¼ 17 Sec 19 N/S 28 E
PERMIT/WAIVER NO. *Issued by Water Resources* 008-121-50 *Current Parcel No.*

Latitude 39.50448 UTM E ☐ NAD 27
Longitude 118.86039 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # Unkown
☒ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Coarse Sand			0	33
Brown Clay			33	36
Brown Sand			36	71
Black Sand			71	75
Black Sand/Gravel			75	94
Brown Sand/Gravel		X	94	110

NAD27
39.504564°N
118.859401°W

Date started: 21-Jul , 20 14
Date completed: 22-Jul , 20 14

9. INSTRUCTION
Depth Drilled: 110 Feet Depth Cased: 110 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	110	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6	4	.316	20	110

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	5	to	105	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	105	to	110	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 0.125

From 107	Feet	To 110	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: 30 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Unkown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89406 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board*: 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 1753-T1
Signed: *By driller performing actual drilling on site or contractor*
Date: 7/23/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.