STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120527
Permit No
Basin No. 083

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 72400
WELL NAME (if applicable)

1. OWNER/CLIENT NAME William & Victoria Sjouangen
MAILING ADDRESS PO BOX 1148
Virgina City Nv 89440

DETAILED ADDRESS AT WELL LOCATION 2461 Grizzley Rd
VCH Reno Nv 89521
Subdivision Name County Storey

2. PLS LOCATION NW ¼ NE ¼ 32 Sec 18 N/S 21 E
PERMIT/WAIVER NO 003-023-16
Issued by Water Resources Permit Number

Latitude 39.38842 UTM E ☐ NAD 27
Longitude -119.64513 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # 92622
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Brown Clay			0	10
light tan rock			10	20
brown clay and tan rock			20	40
multi color rock			40	60
green and grey rock			60	90
black rock			90	100
grey and green rock			100	120
fractured multi colored rock			120	140
fractured green and grey rock			140	170
red volcanic rock			170	180
green and grey clay			180	190
green and grey rock			190	220
red and green rock			220	250
black and red rock			250	360
red and green rock			360	376
NAD27				
39.388420°N				
119.645130°W				
TD 376				

RECEIVED 2014 AUG 15 PM 12:07 STATE ENGINEERS OFFICE

Date started 25-Jul 20 14
Date completed 4-Aug 20 14

7. WATER QUALITIES
Static water level 160 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Airlift	15	280	2 5

9. INSTRUCTION
Depth Drilled: 376 Feet Depth Cased: 376 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8/	Inches	0	Feet	55	Feet
8 1/2	Inches	55	Feet	376	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	376

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 55	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	55	to 276	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Factory
Size of perforation: 3/32 X 3

From 316	Feet	To 356	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge

Name A.S.A.P. Pump & Well Service, LLC.
Contractor
Address P.O. Box 60130 Reno, Nevada 89506
Contractor

Nevada contractor's license number as issued by the State Contractor's Board 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on site driller) 2362

Sign in Larry Welch
Date 8/6/2014

(Rev 12-13)

USE ADDITIONAL SHEETS IF NECESSARY

pg. of pg.

Replacing Well log 92622