STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120547
Permit No.
Basin No. 083

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72202
WELL NAME (if applicable)

1. OWNER/CLIENT NAME: Scott Vickreys
MAILING ADDRESS: 2283 Cartwright Rd
VCH Reno Nv 89521

DETAILED ADDRESS AT WELL LOCATION: 2283 Cartwright Rd
V.C.H. Reno Nv 89521
Subdivision Name: County: Storey

2. PLS LOCATION: SE ¼ NE ¼ 31 Sec 18 N/S 21 E
PERMIT/WAIVER NO. ____ (Issued by Water Resources) 003-015-07 (Consult Pg-Ins No.)

Latitude: 39.38372 UTM E: ____ ☐ NAD 27
Longitude: -119.65728 UTM N: ____ ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
green and grey rock			98	120
grey and white rock			120	150
(Drive Shoe at bottom of hole				
can not be deepend.)				
TD 150				
NAD 27				
39.383808°N				
119.656265°W				

Date started: 5-Aug, 20 14
Date completed: 5-Aug, 20 14

RECEIVED 2014 AUG 15 PM 12:47 STATE ENGINEERS OFFICE

9. INSTRUCTION
Depth Drilled: 150 Feet Depth Cased: 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	98	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.25	188	70	150

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No
☐ Neat Cement ____ to ____ ☐ Pumped ☐ Poured
☐ Cement Grout ____ to ____ ☐ Pumped ☐ Poured
☐ Concrete Grout ____ to ____ ☐ Pumped ☐ Poured
☐ Bentonite Chips ____ to ____ ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] ____ to ____ ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] ____ to ____ ☐ Pumped ☐ Poured
☐ Other, explain: In Place to ____ ☐ Pumped ☐ Poured

PERFORATIONS
Type of perforation: Factory
Size of perforation: 3/32 x 3
From 130 Feet To 150 Feet
From ____ Feet To ____ Feet
From ____ Feet To ____ Feet
From ____ Feet To ____ Feet
From ____ Feet To ____ Feet

7. WATER QUALITIES
Static water level: 110 Feet below land surface
Artesian Flow: ____ G.P.M. ____ P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		30 min

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address: P.O. Box 60130 Reno, Nevada 89506 (Contractor)
Nevada contractor's license number as issued by the Clerk Contractors Board: 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2362
Signed: Larry Welch (Driller performing annual drilling on site of contractor)
Date: 8/6/2014

(Rev 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.