

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 120569
 Permit No. _____
 Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71873

1. OWNER **Chris Miller** ADDRESS AT WELL LOCATION **6505 Pedrol Lane**
 MAILING ADDRESS **2584 Cosimo Ct Sparks, NV** **Winnemucca, NV**
 Subdivision Name: _____ County: **Humboldt**

2. LOCATION **SW¼NW¼ Sec10T36N/ R38E** Latitude **41.00'39.7"** UTM E _____ NAD 27
 PERMIT/WAIVER NO. **N/A** **3638-10-100-002** Longitude **117.41'26.6"** N _____ NAD 83/WGS 84
Issued by Water Resources Parcel. No.

3. WORK PERFORMED New Well Replace Recondition
 Deepen Other

4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	25	25
Course gravel		24	40	15
Sand		40	70	30
Big gravel		70	90	20
Sand/Gravel	X	90	120	30
Clay		120	130	10
Gravel & Clay	X	130	160	30

9. WELL CONSTRUCTION

Depth Drilled **160** Feet Depth Cased **160** Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 5/8 Inches	0 Feet 160 Feet
_____ inches	_____ Feet _____ Feet
_____ inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18	160

Date started: **June 25, 20 14**
 Date completed: **June 26, 20 14**

7. Water Level

Static water level: **35** feet below land surface
 Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.
 Water Temperature: **Cool** °F
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. 13-18		6

Perforations:

Type of perforation **Factory Cut**
 Size of perforation **3/32 x 4**


From	To
120 feet to	160 feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet
_____ feet to	_____ feet

Annular Seal: Yes No

Material	From (Feet)	To (Feet)	Method
<input checked="" type="checkbox"/> Neat Cement	0	50	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	50	160	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
Type:			
Bentonite Chips: <input type="checkbox"/> Yes <input type="checkbox"/> No	_____	_____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
Type:			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Fred Anderson Drilling, Inc.** (CONTRACTOR)
 Address **10760 S. Grass Valley Road** (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board **021467**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**

Signed 
 By driller performing actual drilling on site or contractor
 Date **July 14, 2014**

RECEIVED
 2014 AUG 22 AM 10:48
 STATE ENGINEERS OFFICE
 Replacing unknown well log