STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No 120615
Permit No
Basin No 083

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.120 and NAC 534.340

NOTICE OF INTENT NO 72207
WELL NAME (if issued in)

1. OWNER/CLIENT NAME Lyle Farnsworth
MAILING ADDRESS 602 E Caroline St
Carson City Nv 89701

DETAILED ADDRESS AT WELL LOCATION 1381 Livery Rd
VCH Nv 89521
Subdivision Name County Storey

2. PLS LOCATION ~~NE~~ NW ¼ ~~NW~~ NE ¼ 8 Sec 17N N/S 21 E
PERMIT/WAIVER NO 003-172-06
Issued by Water Resources Current Parcel No

Latitude N 3921.543 UTM E
Longitude W 11938.920 UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen. Orig WL#
☐ Replacement. Original well log #
☐ Recondition. Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Dry	Water Strata	From	To
Brown Clay and Rock			0	5
Brown Rock			5	10
Multi Colored Rock			10	80
Grey and Green Dig			80	130
Red Volcanic Rock			130	135
Multi Colored Rock			135	157
Black Volcanic Rock			157	200
Green and Purple Rock			200	245
TD 245				

NAD 27
39.359138°N
119.647653°W

Date Started 14-Aug 20 14
Date Completed 22-Aug 20 14

7. WATER QUALITIES
Static water level 120 Feet below land surface
Artesian Flow G.P.M. P.S.I.
Water Temperature Cold ° Fahrenheit
Water Quality

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20+		2 hr 25 min

9. INSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	57	Feet
8 1/2	Inches	57	Feet	157	Feet
6 1/8	Inches	157	Feet	245	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	157
5	9.62	188	140	245

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	57	☐ Pumped	☒ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	57	to	157	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation Factory
Size of perforation 3/32 x 3

From	137	Feet	To	157	Feet
From	225	Feet	To	245	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge
Name A.S.A.P Pump & Well Service LLC
Contractor
Address P.O. Box 60130 Reno, Nevada 89506
Contractor
Nevada contractor's license number as issued by the State Contractor's Board 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on site driller) 2362
Signature Larry Welch
8-28-2014

RECEIVED
2014 SEP -2 PM 1:49
STATE ENGINEERS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

pg. of pg.

(Rev. 12-13)