STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 120627
Permit No.
Basin No. 104

NOTICE OF INTENT NO. 72014
WELL NAME (If applicable):

1. OWNER/CLIENT NAME: Verne Rosse
MAILING ADDRESS: 478 Bavarian Dr
Carson City, NV 89705

DETAILED ADDRESS AT WELL LOCATION: 478 Bavarian Dr, Carson City, NV 89705
Subdivision Name: County: Douglas

2. PLS LOCATION: SE ¼ SE ¼ 11 Sec. 14 N/S 19 E
PERMIT/WAIVER NO. 1419-11-002-039
Issued by Water Resources Current Parcel No

Latitude 39.08846 UTM E ☐ NAD 27
Longitude 119.81727 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 14111
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Black and white DG			164	500

NAD27
39.088551°N
119.816256°W

RECEIVED 2014 SEP 1 AM 11:29 STATE ENGINEER'S OFFICE

Date started: 26-Aug, 20 14
Date completed: 2-Sep, 20 14

7. WATER QUALITIES
Static water level: 160 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20+	100	1 HR 20 MIN

9. INSTRUCTION
Depth Drilled: Feet 500 Depth Cased: 500 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	164	Feet	377	Feet
6 1/8	Inches	377	Feet	500	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	147	377
5	9.62	.188	357	500

ANNULAR MATERIALS
Sanitary Seal x ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured
IN PLACE

PERFORATIONS:
Type of perforation: factory
Size of perforation: 3/32 x 3

From	Feet	To	Feet
337	Feet	377	Feet
460	Feet	500	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name McKay Drilling, Inc. (Contractor)
Address 4850 Joule A-5, Reno, NV 89502 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 14170
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2362
Signed: (By driller performing actual drilling on site or contractor)
Date: 9/3/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepens Well log 14111