STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120636
Permit No.
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70669

1. OWNER Round Mountain Gold Corp. DV-14-12
MAILING ADDRESS P.O. Box 480, Round Mountain, NV. 89045

ADDRESS AT WELL LOCATION Round Mountain Mine Site, Round Mountain, NV
Subdivision Name: County: Nye

2. LOCATION SE¼SE¼ Sec24T10N/ R43E
PERMIT/WAIVER NO. M/O-1934 (Issued by Water Resources) Parcel. No.

Latitude Longitude
UTM E 492091 N 4284047 ☒ NAD 27 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	80	80
Clay		80	180	100
Gray Rock		180	280	100
Red Rock		280	360	80

Nad 27
34.706798 N
117.090952 W

Date started: August 18, 20 14
Date completed: August 20, 20 14

RECEIVED 2014 SEP 15 PM 1:30 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	0 Feet	20 Feet
6.75 Inches	20 Feet	360 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.69	.154	+2	360

Perforations:
Type of perforation Slotted
Size of perforation .020
From 60 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 58 to 360 ☐ Pumped ☒ Poured
Type: 3/4 X 1/2 SRI

Bentonite Chips: ☒ Yes ☐ No 20 to 58 ☐ Pumped ☒ Poured
Type: 3/8" Holeplug

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: N/A °F
Quality: N/A

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2462
Signed
By driller performing actual drilling on site or contractor
Date September 4, 2014

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com