STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120637
Permit No.
Basin 13>B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **70669**

1. OWNER **Round Mountain Gold Corp.** **DV-14-11**
MAILING ADDRESS **P.O. Box 480, Round Mountain, NV. 89045**

ADDRESS AT WELL LOCATION **Round Mountain Mine Site, Round Mountain, NV**
Subdivision Name: *County:* **Nye**

2. LOCATION **SE¼SE¼ Sec24T10N/ R43E**
PERMIT/WAIVER NO. **M/O-1934** *Issued by Water Resources* Parcel. No.

Latitude Longitude
UTM E **492091** ☒ NAD 27
N **4283986** ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
Alluvium		0	80	80
Clay		80	180	100
Gray Rock		180	280	100
Red Rock		280	360	80

RECEIVED 2014 SEP 15 PM 1:30 STATE ENGINEERS OFFICE

Nad 27
38.706347 N
117.090456

Date started: **August 21**, 20 **14**
Date completed: **August 22**, 20 **14**

9. *WELL CONSTRUCTION*
Depth Drilled **360** Feet Depth Cased **360** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	**0** Feet	**20** Feet
6.75 Inches	**20** Feet	**360** Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	**.69**	**.154**	**+2**	**360**

Perforations:
Type of perforation **Slotted**
Size of perforation **.020**
From **60** feet to **360** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 58 to 360 ☐ Pumped ☒ Poured
Type: **3/4 X 1/2 SRI**
Bentonite Chips: ☒ Yes ☐ No 20 to 58 ☐ Pumped ☒ Poured
Type: **3/8" Holeplug**

7. *Water Level*
Static water level: **N/A** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
Water Temperature: **N/A** °F
Quality: **N/A**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		**N/A**

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Boart Longyear** (CONTRACTOR)
Address **2745 California Ave.** (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the *State Contractor's Board* **0021976**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2462**
Signed
By driller performing actual drilling on site or contractor
Date **September 4, 2014**