

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 120664
Permit No. 77380
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37404

1 OWNER Mel & Marilyn Larson ADDRESS AT WELL LOCATION 13000 Las Vegas Blvd. So.
MAILING ADDRESS 13000 Las Vegas Blvd. So. Las Vegas NV. 89044 SAME
Subdivision Name: _____ County: Clark

2 LOCATION SW 1/4 SW 1/4 Sec 09 T 23 N/S R 61 E Latitude 35° 57' 20.050" N UTM E NAD 27
PERMIT/WAIVER No. R-1654 191-094-01-010 Longitude 115° 10' 13.096" W N NAD 83/WGS 84
77380 Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Dom - DSI Is this well being plugged because a replacement well was drilled? NO Is there an existing well log? Yes
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor Stock
If yes, what is replacement well NOI? _____ If yes, what is NDWR well log #? 53467, 53460

4 EXISTING WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>		<u>.188</u>	<u>+2</u>	<u>336</u>
<u>6</u>			<u>336</u>	<u>?</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:
Well Was Collapsed At 336 Ft.

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
_____	_____	_____	_____	_____

If casing was left in place, please show where additional perforations were made:

Additional Perforations:

Type of perforator used:	From	feet to	feet	Number of perfs per linear foot
_____	_____	_____	_____	_____

5 WATER LEVEL

Static water level 457 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>TOP</u>	feet to <u>336+</u>	feet	<u>Neat Cement</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet	_____	<input type="checkbox"/>	<input type="checkbox"/>

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started 6-24-14
Date Completed 6-24-14

6 Additional Notes or Comments

This Well Collapsed At 336 Ft. When we Pulled The Pump out of Well, Pump Was Set At 546 Ft.

Pumped 7 1/2 yards Neat Cement To Fill Well

Cut Casing off At Ground Level

DCNR/DWR/SNBO RECEIVED
JUN 26 2014

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Redding Drilling & Pump Contractor
Address P.O. Box 23120 Las Vegas, NV. 89105 Contractor
Nevada contractor's license number _____
issued by the State Contractor's Board
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller

Signed Doyle M. [Signature] By driller performing actual drilling on-site or contractor
Date 6-24-14

STATE ENGINEERS OFFICE
2014 SEP 23 AM 5:50
RECEIVED