STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120678
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37785 ~~32284~~

1. OWNER NDEP AS-5
MAILING ADDRESS 901 S Stewart St. Ste 4001 Carson City NV 89701
ADDRESS AT WELL LOCATION 2152 N. Carson ST Carson City NV. 89706-2254
Subdivision Name County:

2. LOCATION SW ¼ NW ¼ Sec 8 T 15 N/S R 20 E
PERMIT/WAIVER No. AS-5
Issued by Water Resources Parcel No.
Latitude 39 10' 50.10" Longitude 119 46' 03.10"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt, Gravel	X	0	22	22

NAD 27
39.180674°N
119.766513°W

DCNR/DWR/SNBO RECEIVED SEP 09 2014

Date started: 8-27, 20 14
Date completed: 8-27, 20 14

9. WELL CONSTRUCTION
Depth Drilled 22½ Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0 Feet	22½ Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1 15	0.32	0.1333	0	20

Perforations:
Type of perforation PVC
Size of perforation .020 pre-pack
From 20' feet to 22' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	2' to 12'		☒ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 19 to 22½ ☐ Pumped ☐ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 12' to 19' ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: N/A °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

~~STATE ENGINEERS OFFICE~~
~~2014 SEP 16 AM 9:41~~
~~RECEIVED~~

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National ELNP Contractor
Address 5241 Schulls St. Contractor
Las Vegas NV
Nevada contractor's license number issued by the State Contractor's Board 0073535 5
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2492
Signed By driller performing actual drilling on site or contractor
Date 8-27-14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627