STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120684
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~37784~~ 37785

1. OWNER NDEP AS-11
MAILING ADDRESS 901 S Stewart St. Ste 4001
Carson City NV 89701

ADDRESS AT WELL LOCATION 2152 N Carson St
Carson City NV 89706-2254
Subdivision Name: County:

2. LOCATION SW¼ NW¼ Sec 8 T 15 N S R 20 E
PERMIT/WAIVER No. Issued by Water Resources Parcel No.

Latitude 39 10 49.70" Longitude 119 46 02.59
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, gravel	x	0	22	

NAD27
39.180563°N
119.766371°W

DCNR/DWR/SNBO RECEIVED SEP 09 2014

Date started: 8-27, 20 14
Date completed: 8-27, 20 14

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: N/A °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE 2014 SEP 16 AM 10:41 RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	22	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.315	0.32	0.1333	0	20

Perforations:
Type of perforation FALTOFY
Size of perforation .020
From 20 feet to 22 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	1 to 12	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	19 to 12	☒ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No ~~20~~ 19 to 22 ☐ Pumped ☐ Poured
Type: #3 sand
Bentonite Chips: ☒ Yes ☐ No 15 to 19 ☐ Pumped ☒ Poured
Type: 3/8" chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National Exp (Contractor)
Address 5241 Schrills St (Contractor)
Las Vegas NV S
Nevada contractor's license number issued by the State Contractor's Board 0073535S
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2492
Signed (By driller performing actual drilling on-site or contractor)
Date 8-27-14

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627