STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No 120687
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~37784~~ 37785

1. OWNER NDEP MW-27
MAILING ADDRESS 901 S Stewart St. STE 4001 Carson City NV 89701

ADDRESS AT WELL LOCATION 2152 N. Carson ST Carson City NV. 89706-2254
Subdivision Name County:

2. LOCATION SW ¼ NW ¼ Sec 8 T 15N N/S R 20E E
PERMIT/WAIVER No. MW-27
Issued by Water Resources Parcel No.

Latitude 39 10' 49.66" UTM E ☐ NAD 27
Longitude 119 46' 03.75" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand		0	10'	
Silt	12'	10'	20'	
Silty Sand Clay		20'	25'	

DCNR/DWR/SNBO RECEIVED SEP 09 2014

NAD 27
39.180551°N
119.766693°W

Date started: 8/25, 20 14
Date completed: 8/25, 20 14

9. WELL CONSTRUCTION
Depth Drilled 25' ½ Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0	Feet	25' ½	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8	0.68	0.154	0	5'

Perforations
Type of perforation PVC
Size of perforation .020
From 5' feet to 25' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4' to 25' ½ ☐ Pumped ☐ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 2' to 4' ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: N/A °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2014 SEP 16 AM 10:42
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge
Name National EWP
Contractor
Address 5241 Schrills St.
Contractor
Las Vegas NV
Nevada contractor's license number issued by the State Contractor's Board 0075358
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2492
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 8-25-14

(Rev 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627