STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120696
Permit No.
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37777
WELL NAME (if applicable):

1. OWNER/CLIENT NAME: NICK WALDEN
MAILING ADDRESS: 1354 ROSSINI CIRCLE, Henderson NV 89052

DETAILED ADDRESS AT WELL LOCATION: 1131 EAST TROPICANA AVE LAS VEGAS NV
Subdivision Name. County: CLARK

2. PLS LOCATION: NE¼ NE¼ 27 Sec 21 N/S 61 E
PERMIT/WAIVER NO. 1162-27-502-003
Issued by Water Resources Current Parcel No.

Latitude 36.0997 UTM E ☐ NAD 27
Longitude 115.13884 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Asphalt			0	1
Sand and silt			1	5
Caliche			5	17
Clay with Sand Gravel			17	20
Clay with Sand Gravel			20	25
Caliche			25	26
Clay			26	27
Caliche			27	28
Clay			28	30
Caliche			30	34
Clay			34	40
Caliche			40	41
Clay			41	59
Caliche			59	60
Clay			60	80

DCNR/DWR/SNBO
RECEIVED
SEP 09 2014

Date started: 7-16, 20 14
Date completed: 7-21, 20 14

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 80 Feet Depth Cased: 79 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	80 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	79

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	2	to 68	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	68	to 72	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	72	to 80	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Slotted Factory
Size of perforation: .010
From 74 Feet To 79 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: NATIONAL EWP (Contractor)
Address: 5241 Schulis St. LAS VEGAS NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board:
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2492
Signed: (By driller performing actual drilling on site or contractor)
Date: 8-16-14

USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

(Rev. 12-13)

NAD 27
36.0997276
-115.1380036