STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120710
Permit No. 83899T
Basin 031

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71867

1. OWNER Delong Ranches
MAILING ADDRESS 335 Bottle Creek Road

ADDRESS AT WELL LOCATION Cedar Creek Well
Winnemucca, NV 89445
Subdivision Name: N/A County: Humboldt

2. LOCATION NW¼NE¼ Sec10T38N/ R31E
PERMIT/WAIVER NO. 38399T 83899T N/A
Issued by Water Resources Parcel. No.

Latitude 41.11'13.2" UTM E ☐ NAD 27
Longitude 118.29'49.3" N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay/gravel		0	15	15
Rock		15	18	3
Gravel		18	55	32
Clay		55	60	5
Cobles		60	80	20
Clay		80	100	20
Cobble/gravel	X	100	140	40

Map 27
41.187099 N
118.496035 W

RECEIVED 2014 SEP 18 AM 12:37 STATE ENGINEERS OFFICE

Date started: August 1, 20 14
Date completed: August 5, 20 14

7. Water Level
Static water level: 66 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8-10		4

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18"	140

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32 x 4
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 105 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 100 to 105 ☐ Pumped ☒ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed [signature] By driller performing actual drilling on site or contractor
Date Sept 5, 2014

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com