STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120725
Permit No.
Basin 117

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71947

1. OWNER Frank Stamey
MAILING ADDRESS 263 Irene Way Bishop Ca. 93514
ADDRESS AT WELL LOCATION Dyer, NV 89010
Subdivision Name:
County: Esmoralda

2. LOCATION NW ¼ SE ¼ Sec 22 T 2 N/S R 33 E
PERMIT/WAIVER No. 07-151-12
Issued by Water Resources Parcel No.
Latitude N 37°44.933
Longitude W 118° 04.568
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Plugging

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Preforated 6" Casing				
From		50'-100' Ft.		
With Hold Air Preforations				
All the Rest was perfed.				
Installed 2" Trim				
pipe to 240 Feet.				
Mixed # Bentonite				
Grout to 24% And				
Pumped Well Full				
Back to 10' Ft. From				
Surface.				

Date started: June 20, 20 14
Date completed: June 21, 20 14

7. Water Level
Static water level: 108' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
I was on site		
the two days it		
took to plug this		
well with an Employee.		

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
From To
Blew out well to clean out to Bottom at 240 ft.
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

DCNR/DWR/SNBO RECEIVED JUN 27 2014

Perforations:
Type of perforation
Size of perforation
From 50 6 Rows feet to 100' feet
From feet to feet
From 100 feet to 240 Mixed
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 10' ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ 24% Bentonite Grout 10" to 240' ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc.
Contractor
Address PO Box 599
Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841-1740
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Nathinal A. Leach
By driller performing actual drilling on-site or contractor
Date June 25 /2014

(Rev. 05 06)

USE ADDITIONAL SHEETS IF NECESSARY

original well log # 37972

37.7489838
-118.0751851

NAD 27

(NSPO 3-08)

(O) 627