

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120815
Permit No. _____
Basin 219

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 75678

1. OWNER Angel Guzman ADDRESS AT WELL LOCATION 4960 weddle way
MAILING ADDRESS PO Box 1103 Mojave NV 89025
Mojave NV 89025 Subdivision Name: 0 County: Lander Clark

2. LOCATION NE 1/4 NE 1/4 Sec 17 T 14 N R 65 E Latitude 36°43'32.3" N UTM E NAD 27
PERMIT/WAIVER No. 0 073-17-20-004 Longitude 114°43'24.9" W N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand-Boulders</u>		<u>0</u>	<u>145</u>	<u>145</u>
<u>Fractured Rock</u>	<u>X</u>	<u>145</u>	<u>270</u>	<u>125</u>
<u>Hard Rock</u>		<u>270</u>	<u>275</u>	<u>5</u>
<u>7' of 8" steel casing</u>				
<u>was cemented over 6" PVC</u>				
<u>at surface</u>				
DCNR/DWR/SNBO RECEIVED AUG 04 2014				

9. WELL CONSTRUCTION

Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>11</u>	<u>0</u>	<u>275</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>3CH 40</u>	<u>0</u>	<u>275</u>

Perforations:

Type of perforation 39w cut
Size of perforation 1 1/8" x 3"

From 175 feet to 125 feet
From 215 feet to 275 feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout 0 to 50 Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 50 to 275 Pumped Poured
Type: 1/2" minus

Bentonite Chips: Yes No to _____ Pumped Poured
Type: _____

7. Water Level

Static water level: 110 feet below land surface
Artesian Flow: 0 G.P.M. _____ P.S.I.
Water Temperature: cool °F
Quality: Rain

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3</u>		<u>3</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling and Pump Contractor
Address HC 61 Box 54 Contractor
Mojave NV 89017
Nevada contractor's license number _____
issued by the State Contractor's Board 0028266
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller 1191

Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 8-1-2014

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.7221687
-114.732296

NAD 27