STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120818
Permit No.
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36290

1. OWNER JOHN & TERESA STELMASZYK
MAILING ADDRESS HCR 73 BOX 1017
PAHRUMP NV 89061-9201

ADDRESS AT WELL LOCATION 1273 N TROUT CANYON RD
Subdivision Name: County: CLARK

2. LOCATION SW ¼ NE ¼ Sec. 27 T 20S N/S R 56 E
PERMIT/WAIVER No. 134-27-601-043
Issued by Water Resources Parcel No.

Latitude N36°10'57.2" Longitude W115°40'47.0"
UTM E N ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOOSE ROCK & DIRT		0	8	8
LIMESTONE		8	600	592
FRACTRD LIME TRACE		600	650	50
FRCTRD LIME NO STATIC		650	920	270
VOID LOST CIRCULATION		920	923	3
NO RETURNS FRCTRD		923	930	7
VOID		935	937	2
FRCTRD		937	1080	143

DCNR/DWR/SNBO
RECEIVED
SEP 18 2014

Date started: 1-Sep , 20 14
Date completed: 12-Sep , 20 14

9. WELL CONSTRUCTION
Depth Drilled 1060 Feet Depth Cased 1060 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9-7/8	Inches	0	Feet	80	Feet
7-7/8	Inches	80	Feet	1080	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	1060

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 900 feet to 1060 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 60 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 938 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the state driller 1426
Signed (By driller performing actual drilling on site or contractor)
Date 9/17/2014

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.182591
-115.6783724
NAD 27