STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120925
Permit No.
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72412
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Hendrickson, Bryce
MAILING ADDRESS P.O Box 1608
Round Mountain, NV 89405

DETAILED ADDRESS AT WELL LOCATION 475 Senita Court
Round Mountain, NV 89045
Subdivision Name: *County:* Nye

2. PLS LOCATION NW ¼ SE ¼ 4 Sec 10 N/S 43 E
PERMIT/WAIVER NO. 012-461-47
Issued by Water Resources *Current Parcel No.*

Latitude 38.75459 UTM E ☐ NAD 27
Longitude -117.15163 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	32
Brown Clay			32	41
Brown Gravel w/streaks of clay			41	57
Brown Gravel			57	111
Brown Clay			111	123
White/Green Gravel		X	123	155

Nad 27
38.754659°N
117.150716°W

Date started: 23-Sep , 20 14
Date completed: 24-Sep , 20 14

7. *WATER QUALITIES*
Static water level: 17 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25		1 hr

9. *CONSTRUCTION*
Depth Drilled: 155 Feet Depth Cased: 155 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	155

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	5	to 55	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	55	to 155	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Mill Cut
Size of perforation: 1/8"
From 135 Feet To 155 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 Fallon, NV 89406 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2285
Signed: Wayne Pierce (By driller performing actual drilling on site or contractor)
Date: 10-2-2014

RECEIVED 2014 OCT -6 PM 12:34 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.