STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120929
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72073
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME JOHN & JACELYN FISHER
MAILING ADDRESS 1320 N. HWY 395
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 3661 CHEROKEE DR
CARSON CITY, NV 89704
Subdivision Name: *County:* Douglas

2. PLS LOCATION NE ¼ SE ¼ 1 Sec 14 N/S 19 E
PERMIT/WAIVER NO. DOM=14-39 *Issued by Water Resources* 1419-01-701-024 *Current Parcel No.*

Latitude 39.103944-N UTM E ☐ NAD 27
Longitude 119.78905-W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
COURSE DG SANDS			0	65
BROWN CLAY			65	95
DG SANDS			95	168
SILTY SANDS			168	175
DG SANDS AND GRAVELS	XXX		175	240
Nad 27				
39.104035 N				
119.788236 W				

Date started: 26-Aug , 20 14
Date completed: 28-Aug , 20 14

RECEIVED 2014 OCT -7 AM 11:07 STATE ENGINEERS OFFICE

9. *INSTRUCTION*
Depth Drilled: 240 Feet Depth Cased: 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11 1/2	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6 5/8	4.26	.216	20	240
SDR 17				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 60	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	60	to 240	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3 X 3/32

From	Feet	To	Feet
200	Feet	240	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. *WATER QUALITIES*
Static water level: 95 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25	45	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. *Contractor*
Address 20 KIT KAT DRIVE CARSON CITY NV 89706 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: Michael Hack *By driller performing actual drilling on site or contractor*
Date: 9/15/2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.