

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120952
Permit No. _____
Basin No. 092B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72193
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Richard Jones Mailing Address 1289 Lakeview Ave Reno NV 89523
DETAILED ADDRESS AT WELL LOCATION 1530 ESTATES RD
Subdivision Name: _____ County: Washoe

2. PLS LOCATION NE 1/4 SW 1/4 35 Sec 21 N/S 19 E Latitude 39° 39.93 UTM E NAD 27
PERMIT/WAIVER NO. Dom 14-28 020-730-22 Issued by Water Resources Current Parcel No. _____ Longitude 119° 49.33 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____
4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec
5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand & Rock			0	3	3
Clay & Rock			3	45	42
Black Frag.			45	170	125
Clay			170	240	70
Granit Brown			240	-	-
Black & White			240	-	-
Granit			-	310	60
Green White			310	-	-
Granit			-	375	65

9. WELL CONSTRUCTION
Depth Drilled: 375 Feet Depth Cased: 375 Feet
HOLE DIAMETER (BIT SIZE)
From To
11 Inches 0 Feet 55 Feet
9 7/8 Inches 55 Feet 375 Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.108</u>	<u>+2</u>	<u>375</u>

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 1/16
From 295 Feet To 315 Feet
From 335 Feet To 375 Feet
From Feet To Feet

ANNULAR MATERIALS
 Sanitary Seal 0 to 65
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 65 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] 65 to 375 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 7-25-14 , 20
Date completed: 8-1-14 , 20

7. WATER QUALITIES
Static water level: 15.7 Feet below land surface
Artesian Flow: 1.4 G.P.M. 25+ P.S.I.
Water Temperature: Cold ° Fahrenheit
Water Quality: Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
BLAIN DRILLING & PUMP CO INC.
Name P.O. Box 1255
Carson City, NV 89702
Address _____
Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>275 FT</u>	<u>25+</u>	<u>5</u>

Nevada contractor's license number as issued by the State Contractor's Board: 46499A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2321
Signed: C. Robinson
By driller performing actual drilling on site or contractor
Date: 8-1-14

RECEIVED
2014 OCT -9 AM 10:02
STATE ENGINEERS OFFICE

7 Oct 27
39.6404240
119.8211416