

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 120958  
Permit No. \_\_\_\_\_  
Basin 071

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72075

1. OWNER JAMES HARTLEY ADDRESS AT WELL LOCATION NOT GIVEN OUT  
MAILING ADDRESS 10632 ROSE CIR #105 UNK  
VANTURA CA 93004 Subdivision Name: \_\_\_\_\_ County: PERKINS  
2. LOCATION N 1/4 SE 1/4 Sec 33 T 33 N/S R 37 E Latitude UTM E 43 08 93  NAD 27  
PERMIT/WAIVER No. 9527-33-400 Longitude N 4523438  NAD 83/WGS 84  
Parcel No. 003

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
SAND		5	10	
BROWN CLAY		10	50	40
HARD BROWN CLAY		50	80	30
ROCKY CLAY		80	100	
SANDY CLAY		100	120	
SAND		120	130	
BROWN CLAY		130	140	
SANDY CLAY		140	165	
SAND & GRAVEL		165	180	

9. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches From 0 Feet To 180 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.128</u>	<u>+1</u>	<u>180</u>

Perforations:

Type of perforation TORCH CUT

Size of perforation 3/8 x 3 1/2

From 160 feet to 180 feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured

Cement Grout to \_\_\_\_\_  Pumped  Poured

Concrete Grout 5 to 25  Pumped  Poured

80% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 140 to 180  Pumped  Poured

Type: 3/8

Bentonite Chips:  Yes  No 25 to 140  Pumped  Poured

Type: 3/8

Date started: Sept 2 20 14

Date completed: Sept 10 20 14

7. Water Level

Static water level: 33 feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: Cold °F

Quality: Good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Rotary</u>	<u>60+</u>	<u>UNK</u>	<u>2 HRS.</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LBJ DRILLING & PUMP COMPANY, INC. Contractor

Address P.O. BOX 902 - Winnemucca, NV 89446 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0009605A

Nevada driller's license number issued by the Division of Water Resources 1807

Signed Joe Boggio By driller performing actual drilling on site or contractor Joe Boggio

Date 10-08-14

RECEIVED  
2014 OCT -9 AM 11:29  
STATE ENGINEERS OFFICE