STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120961
Permit No.
Basin No. 104

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72368
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME ANN DALLAS
MAILING ADDRESS 638 ARROWHEAD DR
CARSON CITY NV 89706

DETAILED ADDRESS AT WELL LOCATION 638 ARROWHEAD DR
CARSON CITY, NV 89706
Subdivision Name: *County:* Carson City

2. PLS LOCATION NW ¼ NE ¼ 5 Sec 15 N/S 20 E
PERMIT/WAIVER NO. DOM14-47 *Issued by Water Resources* 008-104-06 *Current Parcel No.*

Latitude 39.19894*N UTM E ☐ NAD 27
Longitude 119.761167*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # N/A 92'
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN DG SANDS			3	65
HARD DARK SLATE			65	110
VERY HARD SLATE			110	145
GRAY CLAY SEAM			145	152
FRACTURED SOFT ZONES	XXX		152	200

NAD 27
39.199030°N
119.760152°W

Date started: 7-Oct , 20 14
Date completed: 10-Oct , 20 14

9. INSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	80	Feet
9 7/8	Inches	80	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6	4.26	.216	20	200

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	0	to 60	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	60	to 200	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3 X 3/32

From	Feet	To	Feet
160	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 65 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	35	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC
Contractor
Address 20 KIT KAT DRIVE , CARSON CITY NV 89706
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: *By driller performing actual drilling on site or contractor*
Date: 10/11/2014

RECEIVED 2014 OCT 15 PM 2:22 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replacing Unknown Well log