

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 12988  
Permit No. 71662  
Basin 150

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72229  
Upper Fish Lake well  
Fish Lake NV

1. OWNER Heath Miller ADDRESS AT WELL LOCATION  
MAILING ADDRESS 525 S. Dameron Valley Way  
Dameron Valley Utah 84783  
2. LOCATION S 1/4 SE 1/4 Sec 22 T 10 N R 49 E Latitude \_\_\_\_\_ UTM E 546985.03  NAD 27  
PERMIT/WAIVER No. 71662 Longitude \_\_\_\_\_ N 4281632.99  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name: \_\_\_\_\_ County: NYE

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other...  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay		1	19	18
Brown sand		19	25	6
M.C. gravels, sands	X	25	70	50
Brown clay		70	80	10
M.C. gravels, sands	X	80	285	205

8. WELL CONSTRUCTION  
Depth Drilled 285 Feet Depth Cased 285 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
26" Inches 0 Feet 100 Feet  
24" Inches 100 Feet 285 Feet  
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>20"</u>	<u>95.67</u>	<u>3.75</u>	<u>0</u>	<u>100</u>
<u>16</u>	<u>42.09</u>	<u>2.50</u>	<u>100</u>	<u>285</u>

Perforations:  
Type of perforation Mild steel Screen  
Size of perforation .080  
From 100 feet to 285 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 285 feet

9. WATER LEVEL  
Static water level 5' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature cool °F Quality OK

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Welsco Drilling Corp  
Address P.O. Box 888  
Fallon NV  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller \_\_\_\_\_  
Signed \_\_\_\_\_  
Date 10-16-14

Date started 9-29, 2014  
Date completed 10-5, 2014

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2000</u>		<u>10 hrs</u>

RECEIVED  
2014 OCT 27  
11:27 AM  
DIVISION OF WATER RESOURCES