

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120994
Permit No. _____
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72417
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Gomes, Chris
MAILING ADDRESS 320 St. Clair Rd Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 750 Drumm Ln
Fallon, NV 89406

2. PLS LOCATION NW 1/4 NE 1/4 7 Sec 18 N/S 29 E
PERMIT/WAIVER NO. 006-751-08
Issued by Water Resources Current Parcel No.

Subdivision Name: _____ County: Churchill
Latitude 39.44406 UTM E NAD 27
Longitude -118.76862 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # 8115 ~~no~~
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To |
|------------------------------|------------|--------------|------|-----|
| Brown Sand/Gravel | | | 0 | 26 |
| Black Clay | | | 26 | 33 |
| Black Sand w/streaks of Clay | | | 33 | 68 |
| Black Gravel w/Sand | | | 68 | 74 |
| Black Clay w/Sand | | | 74 | 112 |
| Brown Clay | | | 112 | 116 |
| Brown Silt | | X | 116 | 140 |

9. INSTRUCTION

Depth Drilled: 140 Feet Depth Cased: 140 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From | To |
|--------|------|-----|
| 12 | 0 | 140 |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 12.92 | .188 | +2 | 18 |
| 6 | 3.3 | .255 | 18 | 140 |

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement 5 to 105 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Gravel Pack [> 0.2 in.] 105 to 140 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

PERFORATIONS:

Type of perforation: Saw Cut
Size of perforation: 1/8

From 133 Feet To 140 Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet
 From _____ Feet To _____ Feet

Date started: 16-Sep 2014
Date completed: 17-Sep 2014

7. WATER QUALITIES
Static water level: 17 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265 Fallon, NV 89406
Contractor

8. WELL TEST DATA

| Test Method: | G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|---|--------|-------------------------------|-----------------------|
| <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |

Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1753

Signed: W. J. [Signature]
By driller performing work on site or contractor
Date: 10-6-14

RECEIVED
2014 OCT 21 AM 11:00
STATE ENGINEERS OFFICE

NAID 27
39.444112°N
118.767635°W

Replaces Well log 8115
Plugged by log 122656
Replaced by log 122655