

DRMW-025

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120999
Permit No.
Basin No. 054

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71752
WELL NAME (if applicable): DRAW-025

1. OWNER/CLIENT NAME BARRICK CORP.
MAILING ADDRESS HC-66 Box 1250 Crescent
Valley, NV 89821

DETAILED ADDRESS AT WELL LOCATION N/A
Subdivision Name:
County: EUREKA

2. PLS LOCATION NW 1/4 NW 1/4 03 Sec 28 N/S 49 E
PERMIT/WAIVER NO. MD-923A
Issued by Water Resources Current Parcel No.

Latitude 547437 NAD 27
Longitude 464416 NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [] Deepen: Orig WL#
[] Replacement: Original well log #
[] Recondition: Original well log #

4. PROPOSED USE
[] Domestic
[] Mining / Dewater
[] Test / Other
[] Irrigation
[] Com / Ind
[] Mun / QM
[X] Monitor
[] Stock
[] Rec

5. WELL TYPE
[] Auger [] Rotary [] RVC
[] Air [] Mud [X] Sonic
[] Other

LITHOLOGIC LOG table with columns: Material Encountered, Lost Circ., Water Strata, From, To. Rows include: Tan Sandy Silt & Gravel, Brown Silty sand, Brown Silty Sand & gravel, Brown Silty sand, Brown Silty gravel, Brown Fine grain Sand, Brown Silty clay, Brown Silty sand & gravel, Brown Silty clay, Brown Sandy gravel, Brown Silty clay, Brown Coarse grain Sand, Brown Silty clay, Gray Sandy gravel, Gray Silty clay, Brown Silty sand & gravel.

9. INSTRUCTION
Depth Drilled: 115 Feet Depth Cased: 115 Feet
HOLE DIAMETER (BIT SIZE)
8" From 0 To 115
Inches 0 Feet 115
Inches Feet
Inches Feet

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet). Row: 4" 56.80 0 95

ANNULAR MATERIALS
Sanitary Seal [X] Yes [] No
[] Neat Cement to [] Pumped [] Poured
[] Cement Grout to [] Pumped [] Poured
[X] Concrete Grout 0 to 3 [] Pumped [X] Poured
[X] Bentonite Chips 3/8 3 to 90 [] Pumped [X] Poured
[] Gravel Pack (> 0.2 in.) to [] Pumped [] Poured
[X] Sand Pack (8 1/2 in.) 90 to 115 [] Pumped [X] Poured
[] Other, explain: to [] Pumped [] Poured

PERFORATIONS:
Type of perforation: FACTORY CUT
Size of perforation: .020
From 9.5 Feet To 115 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

Date started: 8-23, 20
Date completed: 8-24, 20

7. WATER QUALITIES-
Static water level: 93.5 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Fahrenheit
Water Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: BOB LONGVEAR Contractor
Address: 605 Union Pacific Way Elko, NV 89801 Contractor

8. WELL TEST DATA table with columns: Test Method (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Recorded Time (Hours). Row: Pumped, 2, .05, 4 hrs

Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site drilled): 2270-m
Signed: [Signature]
Date: 9-20-14
By driller performing actual drilling on site or contractor