STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121017
Permit No.
Basin No. 129

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72411
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Anderson, Cody
MAILING ADDRESS 541 Macbery Las Vegas, NV 89123

DETAILED ADDRESS AT WELL LOCATION Inman Rd
Subdivision Name: *County:* Pershing

2. PLS LOCATION SE ¼ NW ¼ 25 Sec 26 N/S 34 E
PERMIT/WAIVER NO. 015-300-06
Issued by Water Resources *Current Parcel No.*

Latitude 40.09625 UTM E ☐ NAD 27
Longitude -118.10877 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	5
Brown Clay			5	13
Sand			13	28
Sand/Gravel			28	78
Gravel			78	90
Clay/Gravel		X	90	120

NAD 27
40.096338°N
118.107800°W

Date started: 15-Oct , 20 14
Date completed: 17-Oct , 20 14

9. CONSTRUCTION
Depth Drilled: 120 Feet Depth Cased: 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	120

ANNULAR MATERIALS

Sanitary Seal ☐ Yes ☐ No

☒ Neat Cement	0	to	50	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	120	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:

Type of perforation: Mill Cut
Size of perforation: 1/8.

From	Feet	To	Feet
100	Feet	120	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. *WATER QUALITIES*
Static water level: 40 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O Box 1265 Fallon, NV 89407 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2509
Signed: *By driller performing actual drilling on site of contractor*
Date:

RECEIVED 2011 NOV -4 AM 11:25 STATE ENGINEER'S OFFICE

(Rev 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.