STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121018
Permit No.
Basin No. 101A

NOTICE OF INTENT NO. 72413
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Gary Costalupes
MAILING ADDRESS 925 E G Street Sp#1
Oakdale, CA 95361

DETAILED ADDRESS AT WELL LOCATION Coal Canyon Rd.
Lovelock, NV 89419
Subdivision Name: County: Pershing

2. PLS LOCATION NE ¼ SW ¼ 1 Sec. 26 N/S 33 E
PERMIT/WAIVER NO. 015-470-08
Issued by Water Resources Current Parcel No.

Latitude 40.15011 UTM E ☐ NAD 27
Longitude 118.21758 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	3
Sand/Clay			3	7
Brown Clay			7	17
Gray Clay/Rock			17	188
Gray Rock		X	188	375
Gray Clay			375	391
Gray Rock			391	410
Gray Clay			410	413
Gray Rock		X	413	450

NAD27
40.150199°N
118.216607°W

Date started: 20-Oct , 20 14
Date completed: 23-Oct , 20 14

7. WATER QUALITIES
Static water level: 87 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
2		1

9. CONSTRUCTION
Depth Drilled: 450 Feet Depth Cased: 450 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	450	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	450

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to 55	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to 450	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Mill Cut
Size of perforation: .125

From 430	Feet	To 450	Feet
From 210	Feet	To 230	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Fallon, NV 89407 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2509
Signed: By driller performing actual drilling on site or contractor
Date: 10/30/2014

RECEIVED 2014 NOV 14 AM 11:12 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.