STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121040
Permit No.
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72371
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME FRED GREVE
MAILING ADDRESS 290 PERSHING LANE
NEW WASJOE CITY, NV 89704

DETAILED ADDRESS AT WELL LOCATION 290 PERSHING LANE
NEW WASHOE CITY, NV 89704
Subdivision Name: *County:* Washoe

2. PLS LOCATION SE ¼ SE ¼ 31 Sec 17 N/S 20 E
PERMIT/WAIVER NO. *Issued by Water Resources* 050-419-03 *Current Parcel No.*

Latitude 39.289834°N UTM E ☐ NAD 27
Longitude 119.774227°W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig Wl.# N/A
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 6 5/8 WELL			0	100
COURSE DG SANDS			100	145
HARD GRANITE			145	174
GRAY SILTY SANDS AND CLAY			174	210
SMALL DG SANDS & GRAVELS	XX		210	250

NAD 27
39.289924°N
119.773210°W

Date started: 3-Nov , 20 14
Date completed: 4-Nov , 20 14

9. WSTRUCTION
Depth Drilled: 250 ~~158~~ Feet Depth Cased: 250 ~~150~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	100	Feet	250	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Well Thickness (Inches)	From (Feet)	To (Feet)
5"	3.87	.216	90	250
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY SLOT
Size of perforation: 0.032

From	Feet	To	Feet
90		110	
210		250	

7. WATER QUALITIES
Static water level: 68 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15	75	3 HOURS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. *Contractor*
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: Michael Herek *By driller performing actual drilling on site of contractor*
Date: 11/5/2014

RECEIVED 14 NOV 12 AM 11:5 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.