

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121046
Permit No. _____
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72196
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Linda Morris
MAILING ADDRESS 1780 Kathleen Ave

DETAILED ADDRESS AT WELL LOCATION 1780 Kathleen Ave
Subdivision Name: _____
County: Douglas

2. PLS LOCATION N 1/4 NE 1/4 14 Sec 13 N/S 20 E
PERMIT/WAIVER NO. 11320-14-001-006
Issued by Water Resources Current Parcel No.

Latitude 38° 59' 69" UTM E NAD 27
Longitude 119° 42' 09" UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # 90816
 Recondition: Original well log # _____

PROPOSED USE
 Domestic
 Mining / Dewater
 Test / Other
 Irrigation Monitor
 Com / Ind Stock
 Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
<u>SAND - DIRT</u>			<u>0</u>	<u>3</u>	<u>3</u>
<u>SAND - clay</u>			<u>3</u>	<u>32</u>	<u>29</u>
<u>clay</u>			<u>32</u>	<u>94</u>	<u>62</u>
<u>SAND - DS</u>			<u>94</u>	<u>152</u>	<u>58</u>
<u>clay</u>			<u>152</u>	<u>196</u>	<u>44</u>
<u>SAND clay</u>			<u>196</u>	<u>212</u>	<u>16</u>
<u>course SAND</u>			<u>212</u>	<u>340</u>	<u>128</u>

9. WELL CONSTRUCTION
Depth Drilled: 340 Feet
Depth Cased: 340 Feet
HOLE DIAMETER (BIT SIZE)
11 Inches 0 To 340 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>.12</u>	<u>.191</u>	<u>11</u>	<u>20</u>
<u>6"</u>	<u>.14</u>	<u>.202</u>	<u>20</u>	<u>340</u>

PERFORMANCES:
Type of perforation: .060 factory
Size of perforation: .060
From 340 Feet To 290 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS
 Sanitary Seal 0 to 50
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 50 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] 50 to 340 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: Aug 23 :20 14
Date completed: Aug 26 :20 14

7. WATER QUALITIES
Static water level: 110 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 60.0 ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA

Test Method:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)	
<u>104</u>		<u>3</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: **BLAIN DRILLING & PUMP CO INC**
Address: **P.O. Box 1258 Carson City, NV 89702**
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2134
Signed: _____
Date: Sept 15 2014
By driller performing actual drilling on site or contractor