STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121083
Permit No. 75531
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72367
WELL NAME (If applicable):

1. OWNER/CLIENT NAME DONNA BUDDINGTON
MAILING ADDRESS 399 MOTTSVILLE LANE
NW GARDNERVILLE, NV 89460

DETAILED ADDRESS AT WELL LOCATION 399 MOTTSVILLE LANE
GARDNERVILLE, NV 89460
Subdivision Name: County: Douglas

2. PLS LOCATION SE ¼ SW ¼ 28 Sec 12 N/S 19 E
PERMIT/WAIVER NO. 75531 (Issued by Water Resources) 1219-03-002-088 (Current Parcel No.)

Latitude 38.930106*N UTM E ☐ NAD 27
Longitude 119.825211*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN SILTY SANDS			3	9
COUSRSE DG SANDS	X		9	45
DG SILTY SANDS			45	93
GRAY SILTY CLAY ZONE			93	101
RUNNING SILTY SANDS			101	140
COURSR DG SANDS	XXX		140	200

Nad27
38.930149 N
119.824199 W

Date started: 20-Oct, 20 14
Date completed: 21-Oct, 20 14

7. WATER QUALITIES
Static water level: 0 Feet below land surface
Artesian Flow: 10 G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
110	140	6 HRS

9. INSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 1/2 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	8-May	16.34	1.5	200

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	0	to 100	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to 200	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: LOUVERED SCREEN
Size of perforation: FACTORY SLOT

From	Feet	To	Feet
140		200	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0055549
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: Michael Hack
By driller performing actual drilling on site or contractor
Date: 10/27/2014

RECEIVED 2014 NOV 4 AM 10:32 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.