STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121319
Permit No. 83579
Basin 108

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72000

1. OWNER Joe & David Sceirine Ranch
MAILING ADDRESS PO Box 1013 Yerington NV 89447

ADDRESS AT WELL LOCATION Well #2
Subdivision Name: N/A County: Lyon

2. LOCATION NW¼NE¼ Sec34T14N/ R25E
PERMIT/WAIVER NO. 83579 (Issued by Water Resources) N/A (Parcel. No.)

Latitude 39.04016 Longitude 119.17142
UTM E ____ N ____ ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Clay		5	10	5
Sand/gravel		10	25	15
Clay		25	35	10
Gravel	X	35	55	20
Clay		55	60	5
Sand	X	60	85	25
Clay		85	95	10
Gravel/Sand	X	95	140	45

NAD 27
39.040242°N
119.170433°W

RECEIVED 2014 NOV 25 AM 11:31 STATE ENGINEERS OFFICE

Date started: Nov 4, 20 14
Date completed: Nov 5, 20 14

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8.0	.188	+18"	140

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32x4
From 110 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 95 ☒ Pumped ☐ Poured
☐ Cement Grout ____ to ____ ☐ Pumped ☐ Poured
☐ Concrete Grout ____ to ____ ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout ____ to ____ ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 95 to 100 ☐ Pumped ☒ Poured
Type:

7. Water Level
Static water level: 36 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed ____ By driller performing actual drilling on site or contractor
Date Nov 20, 2014