

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 121321
Permit No. 83611-T
Basin 105

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 72171

1 OWNER Town of Minden ADDRESS AT WELL LOCATION 1800 Heybourne Rd.
MAILING ADDRESS 1604 Esmeralda Ave.
Minden, NV 89423 Subdivision Name: _____ County: Douglas

2 LOCATION SE 1/4 SW 1/4 Sec 20 T 13N N/S R 20 E Latitude 38° 58.144 N UTM E NAD 27
PERMIT/WAIVER No. 83611-T 1320-20-000-019 Longitude 119° 45.722 W N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? Yes
If yes, what is replacement well NOI? 72170
Is there an existing well log? Yes
If yes, what is NDWR well log #? 120576

4 EXISTING WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188"	+2'	300'

Existing Perforations:

Type of perforation	Mill Slot
From <u>154'</u> feet to <u>214'</u> feet	<u>.060"</u>
From <u>256'</u> feet to <u>296'</u> feet	
From _____ feet to _____ feet	
From _____ feet to _____ feet	

5 WATER LEVEL
Static water level 28' feet below land surface
Artesian flow No G.P.M. 0 P.S.I.
Water temperature Cool °F Quality _____

6 Additional Notes or Comments

*RECEIVED
2014 NOV 26 AM 11:31
STATE ENGINEERS OFFICE*

NAD 27
38.9691590N
119.7610220W

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:

Additional Perforations:

Type of perforator used:	Holte Air Perforator	
From <u>122'</u> feet to <u>154'</u> feet	Number of perfs per linear foot	<u>6 Row</u>
From <u>214'</u> feet to <u>256'</u> feet	Number of perfs per linear foot	<u>6 Row</u>
From <u>296'</u> feet to <u>300'</u> feet	Number of perfs per linear foot	<u>6 Row</u>
From _____ feet to _____ feet	Number of perfs per linear foot	
From _____ feet to _____ feet	Number of perfs per linear foot	

8 WELL PLUGGING MATERIALS

Material Used			
From <u>0'</u> feet to <u>20'</u> feet	Neat Cement	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>20'</u> feet to <u>300'</u> feet	Bentonite Grout	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____ feet to _____ feet		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Neat Cement Fluid Weight 15lbs lbs/gal
Bentonite Grout 20% % bentonite
Date Started 11/4/2014
Date Completed 11/5/2014

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Stonehouse Drilling and Construction, LLC.
Contractor

Address 7801 Lakeside Drive Reno, NV 89511
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0069994
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #2177

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 11.21.14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

Plugging Well log 120576